

COUNCIL COMMUNICATION

From: The City Manager

Subject: Chlorine Supply Monel Hose and Fittings

Manager's Recommendation:

I recommend that the quote from Powell Fabrication in St. Louis, MI be accepted and that a purchase order be approved and issued to them in the amount of \$2,433.00 for chlorine supply monel hose and fittings.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35-14.44, of the Saginaw Code of Ordinances.

Funds for this work are available in the Water Treatment Parts and Supplies Account No. 591-4730-861-7330.

Justification:

A quote for supply of replacement parts for the Water Treatment Plant (WTP) gaseous chlorine supply system was received in the amount of \$2,433.00 on 2-06-08. Periodic replacement of these parts is required by the WTP Process Safety Management Plan. The MIOSHA Process Safety Management Plan of Highly Hazardous Chemicals Standard requires the plan. The gaseous chlorine system supplies chlorine to the chlorinators. The chlorinators are used to apply chlorine to the raw water supplied to the plant, which disinfects and protects the potable water supply from bacterial contamination.

Powell Fabrication is a sole source distributor in the area for this type of monel chlorine hose.

Council Action:

Council _____ moved that the recommendation of the City Manager be approved.