

COUNCIL COMMUNICATION

From: The City Manager

Subject: ANSI Mag Pump Parts Purchase

Manager's Recommendation:

I recommend acceptance of the only bid received from Detroit Pump and Manufacturing Company, Ferndale, MI and that a purchase order be issued to them in the amount of \$2,732.00 for the purchase of pump parts.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35-14.44, of the Saginaw Code of Ordinances.

Funds for this purchase are available in the Sewer Operation and Maintenance Fund Account No. 590 4835 861 7330

Justification:

On April 8, 2008, the City received a bid for the purchase of a replacement impeller assembly and containment shells for an ANSI Mag pump. This pump delivers the chlorine solution to the treated water at the Weiss Street Retention Treatment Basin (RTB). The pump is currently out of service and waiting for repair parts. The Wastewater Treatment Plant's N.P.D.E.S. Permit requires chlorination of the water, which may be discharged from the RTBs. Only one supplier bid on these replacement parts.

Council Action:

Council _____ moved that the recommendation of the City Manager be approved.