

# COUNCIL COMMUNICATION

**From:** The City Manager

**Subject:** Weirs and Scum Baffle Replacement

**Manager's Recommendation:**

I recommend that the low bid from Warminster Fiberglass Company be accepted and a purchase order be issued to them in the amount of \$42,200.00 for the replacement of weirs and scum baffles.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35-14.44, of the Saginaw Code of Ordinances.

Funds for this purchase are budgeted in the Sewer Repairs and Maintenance Fund Account No. 576-4840-881.97-20.

**Justification:**

The weirs and baffles on the Wastewater Treatment Plants' clarifiers were originally constructed of mild steel. The steel has rusted away and needs to be replaced. Over the next three years, we plan to replace the weirs and baffles on all ten (10) of our clarifiers. The bids received are for the material needed to replace the mild steel weirs and baffles on three clarifiers with fiberglass. Plant personnel will complete the installation. The following is a tabulation of the bids received:

Warminster Fiberglass Co. South Hampton, PA	\$42,200.00
MFG Water Treatment Products Co. Union City, PA	\$42,600.00
NEFCO Inc. Palm Beach Gardens, FL	\$56,640.00
Glass- Steel Inc Woodlands, TX	\$57,317.00

**Council Action:**

Council \_\_\_\_\_ moved that the recommendation of the City Manager be approved.