

COUNCIL COMMUNICATION

From: The City Manager

Subject: Repair Raw Sewage Pump Motor

Manager's Recommendation:

I recommend that a purchase order be issued to Lange and Leaman Electric in the amount of \$3,203.35 for the repair of the raw sewage pump motor for the Wastewater Treatment Plant.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35-14.44, of the Saginaw Code of Ordinances.

Funds for this service are budgeted in the Sewer Operation and Maintenance General Repairs Account No. 590-4830-861.80-40.

Justification:

The raw sewage pumps are required to pump raw wastewater into the Wastewater Treatment Plant. The pump that failed was one of two most frequently used. The motor suddenly lost all its lubricating oil and had to be shut down. Plant maintenance personnel could not diagnose the problem and Lange and Leaman Electric was called in for an emergency repair. Lange and Leaman Electric is the only local company that has experience repairing this type of pump motor for the Wastewater Plant.

Council Action:

Council _____ moved that the recommendation of the City Manager be approved.