

COUNCIL COMMUNICATION

From: The City Manager

Subject: Replacement Flow Meter

Manager's Recommendation:

I recommend that the quote from Emerson Process Management be accepted and a purchase order be issued to them in the amount of \$5,611.00 for a replacement flow meter.

Emerson Process Management is the sole source for Rosemount flow meters in Michigan.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35-14.44, of the Saginaw Code of Ordinances.

Funds for this purchase are budgeted in the Sewer Operation and Maintenance Parts and Supplies Account No. 590-4835-861.73-30.

Justification:

The flow meter for the Salt/Fraser retention basin has failed and needs to be replaced. As retention basin flow meters fail, we have been replacing them with Rosemount meters because they have proven to be the most reliable. This practice also allows us to stock fewer spare parts. Flow meters are required on all the retention basins by our National Pollutant Discharge Elimination System Permit.

Council Action:

Council _____ moved that the recommendation of the City Manager be approved.