

COUNCIL COMMUNICATION

From: The City Manager

Subject: Replacement Isolation Gate

Manager's Recommendation:

I recommend that the quote from Rodney Hunt Company be accepted and that a purchase order be issued to Hesco, their manufacturers representative, in the amount of \$19,155.00.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35-14.44, of the Saginaw Code of Ordinances.

Funds for this service are available in the Sewer Repair and Replacements Account No. 576-4840-881.97-20.

Justification:

One of the isolation gates for the influent flow chamber has deteriorated to the point where it is no longer functional. The gate was removed and found to be beyond repair. These gates are used to isolate portions of the plant influent for routine maintenance of the raw sewage pumps and are part of the original 1948 construction. The replacement gate must be an exact match to the original in order for us to fit it into the existing wall thimbles and allow us to reuse the old stem guides and electric operator. Rodney Hunt Company is a sole source for a replacement isolation gate.

Council Action:

Council _____ moved that the recommendation of the City Manager be approved.