

# COUNCIL COMMUNICATION

**From:** The City Manager

**Subject:** Vertical Inline Centrifugal Pumps

**Manager's Recommendation:**

I recommend acceptance of the low bid and issuance of a purchase order to K. L. McCoy & Associates in the amount of \$5,450.00 for the purchase of two centrifugal pumps for the Wadsworth Pumping Station.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35-14.44, of the Saginaw Code of Ordinances.

Funds for this purchase are budgeted in the Water Treatment Repairs and Replacement Account No. 591-4730-861.97-20.

**Justification:**

On March 24, 2009, the City received four bids for the purchase of two centrifugal pumps. The pumps are for the Wadsworth Pumping Station. The current pumps are obsolete and repair parts are no longer available. The impellers were found to be severely worn during the last inspection and the pumps need to be replaced. The Wadsworth Pumping Station boosts water to the Village of Reese and Blumfield Township. There is no cost comparison available for this item. Following is a tabulation of the bids received:

	<u>Total Bid</u>
K.L. McCoy & Associates Cedar Springs, MI	\$ 5,450.00
Detroit Pump & Mfg. Co. Ferndale, MI	\$ 6,014.00
Kerr Pump & Supply Oak Park, MI	\$ 6,550.00
Anderson Pump & Process Brookfield, WI	\$ 7,740.50

**Council Action:**

Council \_\_\_\_\_ moved that the recommendation of the City Manager be approved.