

COUNCIL COMMUNICATION

From: The City Manager

Subject: Submersible Pump Emergency Repair

Manager's Recommendation:

I recommend approval of the purchase order issued to Hydro Dynamics Inc., Waterford, Michigan, and that payment be made to them in the amount of \$4,835.00 for the emergency repair of the main submersible pump in the drainage well of the Water Treatment Plant.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35 – 14.44, of the Saginaw Code of Ordinances.

Funds for this purchase are budgeted in the Water Treatment Repairs and Replacement Account No. 591-4730-861.80-40.

Justification:

On February 19, 2009 an emergency purchase order was issued to Hydro Dynamics Inc. in the amount of \$4,835.00. The purchase order was for the repair of the main submersible pump in the drainage well of the Water Treatment Plant. The pump is in continuous use and the failure required the installation of a temporary pump and new piping. The emergency purchase was required so we could have the pump back in time for the shutdown and draining of the raw water lines into the plant, that took place on March 27. This work needed to be completed before higher demands for water began. The Maintenance Foreman solicited quotes from several companies, which stated the pump was unrepairable and a new pump was needed. Hydro Dynamics was the only company that stated they could rebuild the pump and electric motor.

Council Action:

Council_____ moved that the recommendation of the City Manager be approved.