

# COUNCIL COMMUNICATION

**From:** The City Manager

**Subject:** Replacement Parts for Dezurik Valve

**Manager's Recommendation:**

I recommend that the quote from Kennedy Industries, Inc. be accepted and that a purchase order be issued to them in the amount of \$4,979.42, for the purchase of parts to rebuild a 16" Dezurik valve.

This vendor meets all requirements of the Contract Compliance Provisions, Title 1, Chapter 14, §14.35-14.44, of the Saginaw Code of Ordinances.

Funds for this service are available in the Sewer Operations & Maintenance Capital Outlay Account No. 590-4830-861.97-05.

**Justification:**

The Dezurik valves are on the discharge side of the raw sewage pump. These valves automatically open when a pump is started and close when it is shut down preventing flow from going backwards through the pump and returning to the wet well. The valve is worn out, leaking, and needs to be refurbished. The valve was originally installed in 1972. Without this valve one of our raw sewage pumps is inoperable. Kennedy Industries is the manufacturers representative for Dezurik valves and, therefore, is a sole source for replacement parts.

**Council Action:**

Council \_\_\_\_\_ moved that the recommendation of the City Manager be approved.