

COUNCIL COMMUNICATION

From: The City Manager

Subject: Replace Drain Piping

Manager's Recommendation:

I recommend acceptance of the only bid from William E. Walter Mechanical Inc. and issuance of purchase order to them in the amount of \$7,450.00 for the replacement of the sanitary drain piping at the Emerson retention basin.

This vendor meets all requirements of the requirements of, §14.23, "Vendors," of "Purchasing, Contracting, and Selling Procedure," of Chapter 14, "Finance and Purchasing," of Title 1, General Provisions" of the Saginaw Code of Ordinances O-1

Funds for this service is budgeted in the Sewer Operation & Maintenance General Repairs Account No. 590-4835-861.80-40.

Justification:

The old cast iron sanitary drain piping for the Emerson retention basin has corroded beyond repair and needs to be replaced. The contractor will remove all the corroded piping and replace it with plastic drain piping.

Council Action:

Council _____ moved that the recommendation of the City Manager be approved.